

- NOTES:
1. P.B. STATION, RUN 3/4" 1/2" 3/4" UP TO EXH. FAN #5 (SAME AS #4)
 2. P.B. STATION, RUN 3/4" 1/2" 3/4" UP TO EXH. FAN #6 (SAME AS #4)
 3. P.B. STATION, RUN 3/4" 1/2" 3/4" UP TO EXH. FAN #7 (SAME AS #4)
 4. P.B. STATION, RUN 3/4" 1/2" 3/4" UP TO EXH. FAN #8 (SAME AS #4)
 5. PANELS "LPT" AND "RPT" SHALL BE MOUNTED WITH BOTTOM 16" AFF. MINIMUM.
 6. ALL HUBS FROM FLOOR OUTLETS IN CASH REGISTER EQUIPMENT ROOM SHALL HAVE ONE #12 GROUND WIRE WITH GREEN INSTALLATION. EXTEND GROUND WIRE TO EACH FLOOR OUTLET. CONNECT GROUND WIRES TO GROUND POST IN PANEL "CR".

