




6. CONNECT TO 2-1P-20A SPARE CIRCUIT BREAKERS IN EXISTING PANEL
"LPA" RUN 3# 12 (BX) C TO LIGHTS AS SHOWN.
7. CONNECT TO 3-1P-20A SPARE CIRCUIT BREAKERS IN EXISTING PANEL
"LPA" RUN 4#12 (BX) TO LIGHTS AS SHOWN.
8. CONNECT TO NEAREST 277V CIRCUIT, MAKE CONNECTION TO LIGHTS AS
REQUIRED

SHEET NO.

E-2

PROJECT NO. 531-2

SEARS, ROEBUCK AND CO. .
ALTERATIONS AND ADDITIONS TO
RETAIL STORE
SECURITY: SQUARE, BALTIMORE, MD.

FEDCO SYSTEMS INC.
10905 FT. WASHINGTON ROAD
FORT WASHINGTON MARYLAND 20744
292-3500-1 645-3337
ARCHITECTS - ENGINEERS - PLANNERS - SURVEYORS



SHEET NO. 25

E-2

PROJECT NO. 531-2

SHEET TITLE:
FIRST FLOOR ~- LIGHTING (QUADRANT I)

STARS

REVISIONS

1001

ISSUED

[illegible]